

# SUMMARY REPORT

For the

TECUMSEH DISTRIBUTION SYSTEM

(260004969)

For the year

2025

Prepared for the Corporation of the Town of Tecumseh  
By Brad Dupuis, C.Tech.  
Manager Water Services O.R.O.

## Table of Contents

Section 1: Overview .....	3
Section 2: Non-compliance Issues .....	4
Section 3: System Capability.....	4

## Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
  - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
  - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking-Water Systems Regulation (O.Reg. 170/03) defines how various drinking-water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

Section 2: Non-Compliance Issues

- 1. During the year of 2025 there was **1 reportable issue**.
  - a) Lead exceedance (distribution system) issued under section 15.1 of O.Reg. 170/03.
    - o March 14, 2025: Area was flushed and resampled.
    - o March 19, 2025: Results of resample were within regulatory limits. Adverse rescinded.

Section 3: System Capability – 2025 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** (87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2025 was 16,392,000 **Litres** (16,320 Cubic Meters) on August 9, 2025.

Monthly average and daily flows for 2025 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh is provided below:

<b>2025 Water Consumption</b>	
<b>Month</b>	<b>Total Volume (cubic meters)</b>
January	235,969
February	212,148
March	231,534
April	253,375
May	304,582
June	356,892
July	441,491
August	442,763
September	428,439
October	370,692
November	291,509
December	256,022
<b>Total</b>	<b>3,825,416</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/02/2025 03:26:00 AM

Report Date From:01/01/2025 12:00:00 AM  
To:01/02/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	559.0	326.0	1627.0	3278.0	0.0	-7.0	6.0	246.0	413.0	471.0	-97.0	N/A	6822.0
2	568.0	346.0	1621.0	3255.0	0.0	-18.0	6.0	267.0	473.0	647.0	-61.0	N/A	7104.0
3	572.0	349.0	1584.0	3216.0	0.0	-19.0	-1.0	292.0	480.0	655.0	-16.0	N/A	7112.0
4	590.0	349.0	1722.0	3446.0	0.0	2.0	20.0	293.0	480.0	656.0	-51.0	N/A	7507.0
5	608.0	372.0	1790.0	3567.0	0.0	-6.0	13.0	315.0	433.0	509.0	-115.0	N/A	7486.0
6	611.0	373.0	1794.0	3575.0	0.0	-19.0	2.0	317.0	487.0	642.0	-79.0	N/A	7703.0
7	574.0	359.0	1630.0	3311.0	0.0	-35.0	-21.0	308.0	494.0	690.0	-25.0	N/A	7285.0
8	580.0	363.0	1632.0	3315.0	0.0	-26.0	-12.0	297.0	503.0	720.0	-4.0	N/A	7368.0
9	569.0	355.0	1613.0	3307.0	0.0	-43.0	-29.0	329.0	530.0	755.0	-12.0	N/A	7374.0
10	568.0	356.0	1615.0	3311.0	0.0	-42.0	-26.0	329.0	530.0	755.0	-13.0	N/A	7383.0
11	589.0	345.0	1789.0	3464.0	0.0	-10.0	1.0	287.0	485.0	657.0	-38.0	N/A	7569.0
12	592.0	355.0	1813.0	3548.0	0.0	-16.0	-1.0	296.0	426.0	512.0	-106.0	N/A	7419.0
13	592.0	360.0	1815.0	3552.0	0.0	-19.0	-2.0	295.0	496.0	655.0	-69.0	N/A	7675.0
14	589.0	361.0	1668.0	3376.0	0.0	-21.0	-10.0	313.0	508.0	688.0	-29.0	N/A	7443.0
15	577.0	355.0	1647.0	3307.0	0.0	-35.0	-28.0	313.0	508.0	701.0	-31.0	N/A	7314.0
16	706.0	441.0	1817.0	3280.0	0.0	-24.0	-13.0	290.0	496.0	701.0	-5.0	N/A	7689.0
17	711.0	443.0	1820.0	3158.0	0.0	-23.0	-13.0	286.0	497.0	701.0	-6.0	N/A	7574.0
18	602.0	355.0	1740.0	3338.0	0.0	-11.0	-1.0	287.0	483.0	658.0	-29.0	N/A	7422.0
19	625.0	371.0	1786.0	3450.0	0.0	-14.0	0.0	321.0	446.0	544.0	-92.0	N/A	7437.0
20	665.0	388.0	1792.0	3463.0	0.0	-20.0	0.0	324.0	496.0	703.0	-59.0	N/A	7752.0
21	685.0	412.0	1680.0	3278.0	0.0	-28.0	-17.0	313.0	507.0	705.0	-32.0	N/A	7503.0
22	693.0	418.0	1692.0	3304.0	0.0	-24.0	-15.0	316.0	508.0	685.0	-32.0	N/A	7545.0
23	677.0	405.0	1688.0	3281.0	0.0	-15.0	-5.0	302.0	501.0	686.0	-23.0	N/A	7497.0
24	1066.0	643.0	2061.0	3846.0	0.0	-23.0	-12.0	304.0	504.0	712.0	-25.0	N/A	9076.0
25	1070.0	645.0	2067.0	3846.0	0.0	0.0	11.0	305.0	504.0	712.0	-36.0	N/A	9124.0
26	737.0	444.0	1895.0	3764.0	0.0	0.0	11.0	304.0	453.0	569.0	-115.0	N/A	8062.0
27	741.0	446.0	1902.0	3764.0	0.0	-7.0	6.0	311.0	511.0	718.0	-75.0	N/A	8317.0
28	717.0	432.0	1726.0	3272.0	0.0	-20.0	-11.0	368.0	583.0	847.0	10.0	N/A	7924.0
29	634.0	386.0	1693.0	3209.0	0.0	-21.0	-10.0	369.0	583.0	847.0	0.0	N/A	7690.0
30	636.0	388.0	1698.0	3209.0	0.0	-22.0	-16.0	321.0	512.0	720.0	-28.0	N/A	7418.0
31	632.0	385.0	1677.0	3191.0	0.0	-23.0	-13.0	312.0	511.0	720.0	-17.0	N/A	7375.0
<b>Monthly To...</b>	<b>20335.00</b>	<b>12326.00</b>	<b>54094.00</b>	<b>105481.00</b>	<b>0.00</b>	<b>-589.00</b>	<b>-180.00</b>	<b>9530.00</b>	<b>15341.00</b>	<b>20941.00</b>	<b>-1310.00</b>	<b>N/A</b>	<b>235969.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/03/2025 03:26:00 AM

Report Date From:01/02/2025 12:00:00 AM  
To:01/03/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	647.0	384.0	1811.0	3427.0	0.0	4.0	17.0	306.0	474.0	652.0	-66.0	N/A	7656.0
2	658.0	398.0	1822.0	3469.0	0.0	5.0	22.0	308.0	435.0	522.0	-109.0	N/A	7530.0
3	661.0	400.0	1672.0	3481.0	0.0	-4.0	15.0	305.0	500.0	682.0	-68.0	N/A	7644.0
4	713.0	435.0	1722.0	3317.0	0.0	-18.0	-5.0	307.0	502.0	690.0	-25.0	N/A	7638.0
5	718.0	440.0	1682.0	3268.0	0.0	-50.0	-32.0	300.0	506.0	705.0	-12.0	N/A	7525.0
6	650.0	405.0	1662.0	3274.0	0.0	-53.0	-37.0	301.0	508.0	722.0	-10.0	N/A	7422.0
7	656.0	414.0	1697.0	3233.0	0.0	-24.0	-9.0	288.0	509.0	723.0	-9.0	N/A	7478.0
8	659.0	415.0	1809.0	3422.0	0.0	-17.0	-1.0	293.0	489.0	686.0	-48.0	N/A	7707.0
9	666.0	410.0	1844.0	3444.0	0.0	-14.0	3.0	300.0	467.0	563.0	-108.0	N/A	7575.0
10	671.0	416.0	1692.0	3457.0	0.0	-14.0	3.0	303.0	506.0	698.0	-69.0	N/A	7663.0
11	671.0	419.0	1663.0	3308.0	0.0	-35.0	-21.0	301.0	513.0	732.0	-17.0	N/A	7534.0
12	668.0	405.0	1685.0	3433.0	0.0	-36.0	-21.0	295.0	515.0	732.0	-5.0	N/A	7671.0
13	664.0	408.0	1657.0	3446.0	0.0	-30.0	-18.0	293.0	503.0	703.0	-9.0	N/A	7617.0
14	657.0	408.0	1686.0	3295.0	0.0	-26.0	-12.0	284.0	489.0	678.0	-16.0	N/A	7443.0
15	661.0	410.0	1767.0	3432.0	0.0	-13.0	-1.0	291.0	480.0	667.0	-42.0	N/A	7652.0
16	649.0	393.0	1745.0	3444.0	0.0	-13.0	-2.0	291.0	437.0	536.0	-94.0	N/A	7386.0
17	660.0	401.0	1767.0	3455.0	0.0	-15.0	2.0	283.0	449.0	572.0	-91.0	N/A	7483.0
18	664.0	411.0	1684.0	3467.0	0.0	-18.0	-3.0	284.0	499.0	710.0	-35.0	N/A	7663.0
19	664.0	412.0	1687.0	3310.0	0.0	-48.0	-35.0	283.0	502.0	711.0	-3.0	N/A	7483.0
20	665.0	413.0	1680.0	3315.0	0.0	-49.0	-37.0	291.0	503.0	722.0	-1.0	N/A	7502.0
21	668.0	417.0	1683.0	3322.0	0.0	-46.0	-33.0	295.0	505.0	723.0	3.0	N/A	7537.0
22	686.0	411.0	1819.0	3575.0	0.0	-22.0	-5.0	310.0	438.0	536.0	-92.0	N/A	7656.0
23	679.0	421.0	1848.0	3594.0	0.0	-20.0	-2.0	321.0	430.0	493.0	-114.0	N/A	7650.0
24	698.0	432.0	1719.0	3389.0	0.0	-16.0	-4.0	318.0	524.0	750.0	-57.0	N/A	7753.0
25	671.0	409.0	1696.0	3290.0	0.0	-39.0	-22.0	300.0	536.0	770.0	-6.0	N/A	7605.0
26	661.0	408.0	1685.0	3267.0	0.0	-44.0	-19.0	268.0	542.0	786.0	5.0	N/A	7559.0
27	653.0	409.0	1680.0	3243.0	0.0	-33.0	-6.0	247.0	548.0	808.0	41.0	N/A	7590.0
28	676.0	423.0	1699.0	3307.0	0.0	-30.0	-5.0	266.0	501.0	662.0	27.0	N/A	7526.0
<b>Monthly To...</b>	<b>18714.00</b>	<b>11527.00</b>	<b>48263.00</b>	<b>94684.00</b>	<b>0.00</b>	<b>-718.00</b>	<b>-268.00</b>	<b>8232.00</b>	<b>13810.00</b>	<b>18934.00</b>	<b>-1030.00</b>	<b>N/A</b>	<b>212148.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/04/2025 03:26:00 AM

Report Date From:01/03/2025 12:00:00 AM  
To:01/04/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	700.0	433.0	1750.0	3537.0	N/A	-22.0	-8.0	345.0	446.0	495.0	-4.0	N/A	7672.0
2	687.0	426.0	1854.0	3582.0	N/A	-16.0	2.0	327.0	435.0	486.0	-14.0	N/A	7769.0
3	662.0	408.0	1675.0	3239.0	0.0	-35.0	-18.0	321.0	520.0	743.0	-14.0	N/A	7501.0
4	665.0	409.0	1681.0	3251.0	0.0	-36.0	-19.0	322.0	522.0	744.0	-19.0	N/A	7520.0
5	653.0	401.0	1666.0	3236.0	0.0	-42.0	-25.0	331.0	526.0	745.0	-20.0	N/A	7471.0
6	664.0	413.0	1686.0	3273.0	0.0	-36.0	-14.0	332.0	528.0	760.0	-2.0	N/A	7604.0
7	670.0	417.0	1692.0	3284.0	0.0	-26.0	-10.0	311.0	527.0	761.0	23.0	N/A	7649.0
8	680.0	405.0	1799.0	3421.0	0.0	-16.0	2.0	317.0	459.0	569.0	-61.0	N/A	7575.0
9	636.0	384.0	1725.0	3288.0	0.0	-21.0	4.0	274.0	405.0	464.0	-82.0	N/A	7077.0
10	1217.0	770.0	2561.0	1022.0	0.0	-1.0	17.0	314.0	528.0	775.0	28.0	N/A	7231.0
11	1500.0	948.0	2986.0	1.0	0.0	15.0	48.0	301.0	521.0	771.0	39.0	N/A	7130.0
12	1510.0	963.0	3006.0	0.0	0.0	29.0	41.0	291.0	526.0	793.0	47.0	N/A	7206.0
13	1518.0	968.0	3018.0	1946.0	0.0	19.0	30.0	306.0	528.0	794.0	27.0	N/A	9154.0
14	654.0	405.0	1666.0	3162.0	0.0	-28.0	-5.0	311.0	517.0	737.0	7.0	N/A	7426.0
15	622.0	383.0	1744.0	3240.0	0.0	10.0	28.0	289.0	441.0	555.0	-58.0	N/A	7254.0
16	679.0	416.0	1823.0	3393.0	0.0	-5.0	20.0	295.0	424.0	473.0	-109.0	N/A	7409.0
17	678.0	420.0	1678.0	3169.0	0.0	-32.0	-17.0	318.0	512.0	720.0	-4.0	N/A	7442.0
18	657.0	411.0	1666.0	3134.0	0.0	-32.0	-19.0	290.0	496.0	720.0	0.0	N/A	7323.0
19	640.0	401.0	1661.0	3136.0	0.0	-24.0	-11.0	293.0	508.0	736.0	15.0	N/A	7355.0
20	627.0	398.0	1644.0	3101.0	0.0	-15.0	2.0	302.0	504.0	715.0	1.0	N/A	7279.0
21	640.0	406.0	1652.0	3133.0	0.0	-27.0	-10.0	325.0	516.0	741.0	6.0	N/A	7382.0
22	678.0	419.0	1772.0	3332.0	0.0	-13.0	7.0	291.0	435.0	541.0	-61.0	N/A	7401.0
23	704.0	426.0	1827.0	3414.0	0.0	-7.0	16.0	286.0	418.0	473.0	-101.0	N/A	7456.0
24	661.0	405.0	1640.0	3123.0	0.0	-46.0	-25.0	303.0	488.0	677.0	-59.0	N/A	7167.0
25	650.0	404.0	1638.0	3110.0	0.0	-43.0	-23.0	292.0	504.0	715.0	-3.0	N/A	7244.0
26	664.0	407.0	1644.0	3122.0	0.0	-31.0	-15.0	316.0	527.0	748.0	4.0	N/A	7386.0
27	685.0	410.0	1646.0	3130.0	0.0	-26.0	-8.0	328.0	550.0	800.0	17.0	N/A	7532.0
28	687.0	409.0	1627.0	3083.0	0.0	-21.0	-3.0	329.0	551.0	802.0	24.0	N/A	7488.0
29	692.0	410.0	1778.0	3530.0	0.0	-16.0	5.0	294.0	434.0	520.0	-75.0	N/A	7572.0
30	700.0	417.0	1803.0	3362.0	0.0	-15.0	10.0	290.0	426.0	483.0	-87.0	N/A	7389.0
31	662.0	414.0	1809.0	3114.0	0.0	-28.0	-7.0	302.0	509.0	725.0	-30.0	N/A	7470.0
<b>Monthly To...</b>	<b>23742.00</b>	<b>14706.00</b>	<b>57817.00</b>	<b>90868.00</b>	<b>0.00</b>	<b>-587.00</b>	<b>-5.00</b>	<b>9546.00</b>	<b>15231.00</b>	<b>20781.00</b>	<b>-565.00</b>	<b>N/A</b>	<b>231534.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/05/2025 03:26:00 AM

Report Date From:01/04/2025 12:00:00 AM  
To:01/05/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	652.0	401.0	1623.0	3120.0	0.0	-39.0	-19.0	312.0	515.0	739.0	9.0	N/A	7313.0
2	682.0	418.0	1635.0	3137.0	0.0	-32.0	-12.0	303.0	492.0	697.0	-9.0	N/A	7311.0
3	695.0	427.0	1674.0	3199.0	0.0	-29.0	-10.0	303.0	505.0	709.0	-4.0	N/A	7469.0
4	773.0	459.0	1709.0	3231.0	0.0	-12.0	8.0	294.0	494.0	701.0	-6.0	N/A	7651.0
5	742.0	444.0	1802.0	3404.0	0.0	9.0	30.0	284.0	418.0	499.0	-80.0	N/A	7552.0
6	764.0	460.0	1852.0	3510.0	0.0	-1.0	27.0	287.0	411.0	452.0	-105.0	N/A	7657.0
7	807.0	504.0	1717.0	3254.0	0.0	-18.0	3.0	329.0	509.0	691.0	-29.0	N/A	7767.0
8	685.0	429.0	1670.0	3200.0	0.0	-22.0	-4.0	307.0	507.0	727.0	-2.0	N/A	7497.0
9	688.0	430.0	1676.0	3212.0	0.0	-23.0	-5.0	330.0	542.0	790.0	10.0	N/A	7650.0
10	679.0	423.0	1676.0	3219.0	0.0	-19.0	-4.0	333.0	543.0	791.0	9.0	N/A	7650.0
11	817.0	513.0	1766.0	3261.0	0.0	-10.0	7.0	305.0	493.0	705.0	-8.0	N/A	7849.0
12	821.0	515.0	1851.0	3463.0	0.0	2.0	24.0	304.0	483.0	672.0	-35.0	N/A	8100.0
13	783.0	476.0	1879.0	3517.0	0.0	5.0	27.0	317.0	440.0	536.0	-100.0	N/A	7880.0
14	789.0	497.0	1886.0	3529.0	0.0	9.0	20.0	324.0	537.0	781.0	-48.0	N/A	8324.0
15	815.0	507.0	1862.0	3390.0	0.0	-1.0	12.0	368.0	627.0	953.0	54.0	N/A	8587.0
16	850.0	520.0	1838.0	3424.0	0.0	8.0	25.0	329.0	545.0	796.0	16.0	N/A	8351.0
17	920.0	563.0	1900.0	3641.0	0.0	24.0	36.0	315.0	506.0	716.0	-3.0	N/A	8618.0
18	835.0	494.0	1910.0	3527.0	0.0	29.0	46.0	284.0	424.0	505.0	-97.0	N/A	7957.0
19	835.0	482.0	1912.0	3555.0	0.0	12.0	24.0	300.0	426.0	475.0	-100.0	N/A	7921.0
20	832.0	478.0	1878.0	3532.0	0.0	-23.0	-3.0	327.0	433.0	460.0	-133.0	N/A	7781.0
21	829.0	499.0	1813.0	3425.0	0.0	-15.0	1.0	345.0	511.0	694.0	-92.0	N/A	8010.0
22	1080.0	662.0	2052.0	3931.0	0.0	-6.0	20.0	334.0	539.0	781.0	0.0	N/A	9393.0
23	1188.0	700.0	2112.0	3945.0	0.0	9.0	19.0	319.0	575.0	863.0	23.0	N/A	9753.0
24	1223.0	731.0	2234.0	4017.0	0.0	31.0	25.0	331.0	582.0	878.0	26.0	N/A	10078.0
25	1241.0	744.0	2254.0	4052.0	0.0	20.0	35.0	349.0	584.0	880.0	22.0	N/A	10181.0
26	1170.0	681.0	2107.0	3829.0	0.0	39.0	56.0	335.0	564.0	829.0	1.0	N/A	9611.0
27	1038.0	598.0	2160.0	4000.0	0.0	47.0	63.0	319.0	452.0	557.0	-82.0	N/A	9152.0
28	1266.0	744.0	2273.0	4113.0	0.0	47.0	63.0	348.0	569.0	823.0	-30.0	N/A	10216.0
29	1236.0	707.0	2209.0	4082.0	0.0	31.0	43.0	325.0	572.0	848.0	15.0	N/A	10068.0
30	1228.0	726.0	2234.0	4060.0	0.0	27.0	41.0	349.0	558.0	803.0	2.0	N/A	10028.0
<b>Monthly To...</b>	<b>26963.00</b>	<b>16232.00</b>	<b>57164.00</b>	<b>106779.00</b>	<b>0.00</b>	<b>99.00</b>	<b>598.00</b>	<b>9609.00</b>	<b>15356.00</b>	<b>21351.00</b>	<b>-776.00</b>	<b>N/A</b>	<b>253375.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/06/2025 03:26:00 AM

Report Date From:01/05/2025 12:00:00 AM  
To:01/06/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1113.0	660.0	2111.0	3858.0	0.0	25.0	38.0	306.0	517.0	745.0	-2.0	N/A	9371.0
2	986.0	590.0	2012.0	3698.0	0.0	0.0	24.0	324.0	528.0	740.0	-12.0	N/A	8890.0
3	984.0	602.0	2085.0	3815.0	0.0	7.0	45.0	301.0	440.0	534.0	-79.0	N/A	8734.0
4	991.0	603.0	2102.0	3852.0	0.0	-36.0	13.0	347.0	446.0	453.0	-133.0	N/A	8638.0
5	1105.0	674.0	2091.0	3798.0	0.0	-24.0	4.0	328.0	527.0	744.0	-84.0	N/A	9163.0
6	1092.0	671.0	2090.0	3784.0	0.0	22.0	49.0	305.0	519.0	746.0	-7.0	N/A	9271.0
7	1104.0	682.0	2140.0	3924.0	0.0	6.0	34.0	343.0	556.0	792.0	-2.0	N/A	9579.0
8	1292.0	823.0	2276.0	4079.0	0.0	3.0	32.0	345.0	551.0	793.0	3.0	N/A	10197.0
9	1229.0	754.0	2278.0	4245.0	0.0	37.0	71.0	334.0	542.0	780.0	2.0	N/A	10272.0
10	1305.0	781.0	2499.0	4562.0	0.0	28.0	59.0	356.0	500.0	599.0	-87.0	N/A	10602.0
11	1165.0	719.0	2442.0	4462.0	0.0	26.0	68.0	355.0	474.0	543.0	-125.0	N/A	10129.0
12	1317.0	808.0	2435.0	4582.0	0.0	41.0	64.0	391.0	631.0	922.0	-57.0	N/A	11134.0
13	1142.0	687.0	2152.0	4063.0	0.0	38.0	59.0	342.0	576.0	834.0	-12.0	N/A	9881.0
14	1211.0	743.0	2256.0	4272.0	0.0	46.0	73.0	339.0	577.0	829.0	-10.0	N/A	10336.0
15	1210.0	736.0	2302.0	4378.0	0.0	-7.0	141.0	365.0	622.0	909.0	3.0	N/A	10659.0
16	1303.0	779.0	2387.0	4349.0	0.0	-3.0	43.0	355.0	553.0	735.0	-21.0	N/A	10480.0
17	1030.0	589.0	2157.0	3943.0	0.0	-7.0	-1.0	325.0	441.0	480.0	-115.0	N/A	8842.0
18	1125.0	665.0	2271.0	4166.0	0.0	31.0	20.0	327.0	446.0	488.0	-102.0	N/A	9437.0
19	1164.0	677.0	2321.0	4244.0	0.0	33.0	49.0	347.0	484.0	508.0	-136.0	N/A	9691.0
20	1170.0	680.0	2329.0	4259.0	0.0	27.0	47.0	362.0	577.0	874.0	-81.0	N/A	10244.0
21	1080.0	642.0	2065.0	3819.0	0.0	-8.0	14.0	366.0	589.0	876.0	2.0	N/A	9445.0
22	982.0	608.0	1938.0	3584.0	0.0	-9.0	11.0	356.0	581.0	881.0	8.0	N/A	8940.0
23	1019.0	611.0	1993.0	3686.0	0.0	-15.0	5.0	343.0	548.0	801.0	-8.0	N/A	8983.0
24	1079.0	639.0	2207.0	4001.0	0.0	30.0	55.0	344.0	547.0	800.0	-31.0	N/A	9671.0
25	1183.0	697.0	2363.0	4298.0	0.0	44.0	60.0	343.0	470.0	572.0	-120.0	N/A	9910.0
26	1195.0	706.0	2372.0	4322.0	0.0	34.0	49.0	392.0	590.0	785.0	-84.0	N/A	10361.0
27	1208.0	722.0	2324.0	4338.0	0.0	23.0	48.0	398.0	605.0	831.0	-34.0	N/A	10463.0
28	1227.0	733.0	2293.0	4208.0	0.0	7.0	29.0	402.0	609.0	832.0	-30.0	N/A	10310.0
29	1222.0	723.0	2249.0	4174.0	0.0	5.0	8.0	364.0	574.0	804.0	-22.0	N/A	10101.0
30	1265.0	754.0	2337.0	4242.0	0.0	9.0	1.0	368.0	577.0	807.0	-29.0	N/A	10331.0
31	1279.0	763.0	2397.0	4363.0	0.0	36.0	48.0	393.0	572.0	768.0	-102.0	N/A	10517.0
<b>Monthly To...</b>	<b>35777.00</b>	<b>21521.00</b>	<b>69274.00</b>	<b>127368.00</b>	<b>0.00</b>	<b>449.00</b>	<b>1260.00</b>	<b>10866.00</b>	<b>16769.00</b>	<b>22805.00</b>	<b>-1507.00</b>	<b>N/A</b>	<b>304582.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/07/2025 03:26:00 AM

Report Date From:01/06/2025 12:00:00 AM  
To:01/07/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1423.0	844.0	2726.0	4958.0	0.0	27.0	44.0	456.0	509.0	602.0	-168.0	N/A	11421.0
2	1472.0	876.0	2735.0	4999.0	0.0	70.0	91.0	474.0	N/A	1022.0	-112.0	N/A	11627.0
3	1623.0	976.0	2844.0	5207.0	0.0	91.0	117.0	485.0	710.0	1023.0	-22.0	N/A	13054.0
4	1631.0	981.0	2855.0	5226.0	0.0	90.0	119.0	488.0	712.0	1026.0	-31.0	N/A	13097.0
5	1530.0	945.0	2760.0	4971.0	0.0	21.0	44.0	461.0	691.0	960.0	-41.0	N/A	12342.0
6	1303.0	798.0	2412.0	4386.0	0.0	38.0	68.0	358.0	553.0	774.0	-8.0	N/A	10682.0
7	1411.0	842.0	2649.0	4708.0	0.0	40.0	69.0	400.0	554.0	774.0	-44.0	N/A	11403.0
8	1418.0	846.0	2659.0	4724.0	0.0	34.0	60.0	402.0	537.0	629.0	-94.0	N/A	11215.0
9	1422.0	844.0	2303.0	4577.0	0.0	30.0	51.0	397.0	601.0	829.0	-54.0	N/A	11000.0
10	1423.0	848.0	2498.0	4594.0	0.0	27.0	35.0	439.0	676.0	988.0	-12.0	N/A	11516.0
11	1556.0	943.0	2818.0	2347.0	0.0	36.0	45.0	458.0	729.0	1065.0	-15.0	N/A	9982.0
12	1592.0	960.0	2829.0	1648.0	0.0	37.0	45.0	460.0	731.0	1066.0	-17.0	N/A	9351.0
13	1254.0	761.0	2473.0	4003.0	0.0	14.0	29.0	402.0	613.0	862.0	-41.0	N/A	10370.0
14	1267.0	744.0	2560.0	4210.0	0.0	36.0	62.0	367.0	513.0	629.0	-106.0	N/A	10282.0
15	1463.0	863.0	2826.0	4731.0	0.0	63.0	76.0	428.0	558.0	626.0	-136.0	N/A	11498.0
16	1596.0	942.0	2888.0	4964.0	0.0	24.0	38.0	488.0	714.0	967.0	-85.0	N/A	12536.0
17	1577.0	924.0	2887.0	4994.0	0.0	30.0	18.0	467.0	753.0	1105.0	-21.0	N/A	12734.0
18	1210.0	738.0	2386.0	4163.0	0.0	-2.0	-40.0	392.0	642.0	918.0	-9.0	N/A	10398.0
19	1373.0	829.0	2405.0	4138.0	0.0	11.0	1.0	358.0	593.0	858.0	-3.0	N/A	10563.0
20	1376.0	780.0	2423.0	4200.0	0.0	14.0	12.0	366.0	572.0	783.0	0.0	N/A	10526.0
21	1302.0	781.0	2511.0	4377.0	0.0	40.0	64.0	348.0	528.0	665.0	-16.0	N/A	10600.0
22	1717.0	1024.0	3070.0	5268.0	0.0	40.0	71.0	395.0	586.0	656.0	-54.0	N/A	12773.0
23	1767.0	1062.0	3096.0	5244.0	0.0	44.0	65.0	433.0	713.0	983.0	-24.0	N/A	13383.0
24	1774.0	1016.0	2957.0	5076.0	0.0	28.0	5.0	415.0	702.0	976.0	-33.0	N/A	12916.0
25	1625.0	998.0	2800.0	4854.0	0.0	-35.0	-24.0	502.0	795.0	1147.0	-4.0	N/A	12658.0
26	1683.0	1020.0	2844.0	4889.0	0.0	53.0	79.0	383.0	640.0	945.0	33.0	N/A	12569.0
27	1959.0	1188.0	3250.0	5713.0	0.0	22.0	-7.0	415.0	664.0	908.0	-35.0	N/A	14077.0
28	2053.0	1233.0	3518.0	6187.0	0.0	95.0	123.0	455.0	623.0	736.0	-98.0	N/A	14925.0
29	2047.0	1230.0	3488.0	6161.0	0.0	73.0	84.0	458.0	619.0	668.0	-83.0	N/A	14745.0
30	1723.0	1032.0	3022.0	5323.0	0.0	23.0	41.0	177.0	620.0	776.0	-88.0	N/A	12649.0
<b>Monthly To...</b>	<b>46570.00</b>	<b>27868.00</b>	<b>83492.00</b>	<b>140840.00</b>	<b>0.00</b>	<b>1114.00</b>	<b>1485.00</b>	<b>12527.00</b>	<b>18451.00</b>	<b>25966.00</b>	<b>-1421.00</b>	<b>N/A</b>	<b>356892.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/08/2025 03:26:00 AM

Report Date From:01/07/2025 12:00:00 AM  
To:01/08/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1914.0	1141.0	3314.0	5901.0	0.0	87.0	109.0	463.0	692.0	917.0	-39.0	N/A	14499.0
2	2010.0	1220.0	3355.0	6038.0	0.0	22.0	35.0	538.0	781.0	1033.0	-94.0	N/A	14938.0
3	2335.0	1445.0	3716.0	6531.0	0.0	106.0	150.0	485.0	751.0	1056.0	-62.0	N/A	16513.0
4	2321.0	1385.0	3672.0	6538.0	0.0	80.0	116.0	520.0	742.0	974.0	-112.0	N/A	16236.0
5	2151.0	1282.0	3574.0	6413.0	0.0	120.0	169.0	446.0	653.0	806.0	-44.0	N/A	15570.0
6	2222.0	1306.0	3657.0	6439.0	0.0	111.0	150.0	483.0	654.0	735.0	-84.0	N/A	15673.0
7	2226.0	1308.0	3665.0	6454.0	0.0	109.0	139.0	501.0	754.0	1059.0	-84.0	N/A	16131.0
8	1955.0	1149.0	3335.0	6005.0	0.0	86.0	102.0	503.0	756.0	1060.0	-52.0	N/A	14899.0
9	1916.0	1163.0	3088.0	5446.0	0.0	28.0	50.0	441.0	713.0	1028.0	-30.0	N/A	13843.0
10	2121.0	1328.0	3313.0	5822.0	0.0	63.0	85.0	415.0	684.0	994.0	-9.0	N/A	14816.0
11	1795.0	1069.0	3051.0	5524.0	0.0	27.0	48.0	448.0	670.0	940.0	-79.0	N/A	13493.0
12	1675.0	1010.0	2910.0	5185.0	0.0	61.0	84.0	360.0	545.0	680.0	-89.0	N/A	12421.0
13	1815.0	1085.0	3091.0	5482.0	0.0	89.0	116.0	372.0	537.0	614.0	-79.0	N/A	13122.0
14	2026.0	1186.0	3337.0	5965.0	0.0	77.0	100.0	436.0	693.0	980.0	-26.0	N/A	14774.0
15	2066.0	1193.0	3357.0	5997.0	0.0	48.0	75.0	455.0	728.0	1054.0	-32.0	N/A	14941.0
16	1832.0	1101.0	3017.0	5360.0	0.0	-13.0	18.0	437.0	709.0	1031.0	-36.0	N/A	13456.0
17	1554.0	974.0	2689.0	4973.0	0.0	-24.0	1.0	443.0	702.0	1044.0	-52.0	N/A	12304.0
18	1771.0	1065.0	3036.0	5450.0	0.0	12.0	39.0	507.0	706.0	1046.0	-117.0	N/A	13515.0
19	2043.0	1241.0	3335.0	5960.0	0.0	80.0	137.0	509.0	707.0	943.0	-163.0	N/A	14792.0
20	2050.0	1245.0	2891.0	5978.0	0.0	97.0	124.0	439.0	600.0	721.0	-147.0	N/A	13998.0
21	1787.0	1054.0	3093.0	5643.0	0.0	70.0	78.0	467.0	726.0	1039.0	-106.0	N/A	13851.0
22	1795.0	1059.0	3090.0	5672.0	0.0	64.0	65.0	479.0	758.0	1106.0	-36.0	N/A	14052.0
23	1947.0	1204.0	3310.0	6173.0	0.0	54.0	74.0	521.0	820.0	1187.0	-39.0	N/A	15251.0
24	2070.0	1285.0	3368.0	6196.0	0.0	40.0	58.0	523.0	821.0	1188.0	-62.0	N/A	15487.0
25	2078.0	1290.0	2880.0	6199.0	0.0	13.0	1.0	480.0	768.0	1093.0	-103.0	N/A	14699.0
26	1647.0	977.0	2687.0	5416.0	0.0	28.0	68.0	440.0	700.0	756.0	-128.0	N/A	12591.0
27	1419.0	856.0	2900.0	5385.0	0.0	59.0	91.0	431.0	623.0	743.0	-119.0	N/A	12388.0
28	1673.0	974.0	2976.0	5418.0	0.0	66.0	33.0	432.0	686.0	954.0	-68.0	N/A	13144.0
29	1674.0	973.0	2810.0	5430.0	0.0	35.0	56.0	421.0	696.0	1030.0	-45.0	N/A	13080.0
30	1833.0	1114.0	3091.0	5564.0	0.0	40.0	67.0	414.0	697.0	1013.0	-63.0	N/A	13770.0
31	1847.0	1124.0	2596.0	5589.0	0.0	49.0	82.0	416.0	692.0	846.0	3.0	N/A	13244.0
<b>Monthly To...</b>	<b>59568.00</b>	<b>35806.00</b>	<b>98204.00</b>	<b>180146.00</b>	<b>0.00</b>	<b>1784.00</b>	<b>2520.00</b>	<b>14225.00</b>	<b>21764.00</b>	<b>29670.00</b>	<b>-2196.00</b>	<b>N/A</b>	<b>441491.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports  
M\_FlowTotal\_Net\_MCx  
04/09/2025 12:38:19 PM

Report Date From: 01/08/2025 12:00:00 AM

To: 01/09/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1628.0	978.0	2826.0	5082.0	0.0	60.0	80.0	393.0	623.0	843.0	-48.0	N/A	12465.0
2	1892.0	1175.0	3215.0	5744.0	0.0	91.0	117.0	419.0	625.0	680.0	-127.0	N/A	13831.0
3	1899.0	1179.0	3238.0	5782.0	0.0	91.0	120.0	421.0	586.0	674.0	-152.0	N/A	13838.0
4	2209.0	1321.0	3584.0	6262.0	0.0	111.0	135.0	443.0	640.0	747.0	-185.0	N/A	15267.0
5	2218.0	1326.0	3466.0	6030.0	0.0	111.0	111.0	472.0	727.0	1008.0	-152.0	N/A	15317.0
6	2189.0	1264.0	3419.0	6119.0	0.0	85.0	114.0	457.0	715.0	943.0	-105.0	N/A	15200.0
7	2119.0	1313.0	3565.0	6224.0	0.0	72.0	95.0	459.0	737.0	1036.0	-81.0	N/A	15539.0
8	2305.0	1353.0	3687.0	6592.0	0.0	77.0	105.0	502.0	753.0	987.0	-152.0	N/A	16209.0
9	2298.0	1395.0	3814.0	6776.0	0.0	110.0	136.0	501.0	702.0	816.0	-156.0	N/A	16392.0
10	2058.0	1231.0	3598.0	6520.0	0.0	108.0	128.0	518.0	700.0	786.0	-121.0	N/A	15526.0
11	1942.0	1100.0	3253.0	5970.0	0.0	48.0	73.0	482.0	753.0	1040.0	-152.0	N/A	14509.0
12	1529.0	895.0	2393.0	4375.0	0.0	23.0	44.0	359.0	639.0	996.0	-74.0	N/A	11179.0
13	1924.0	1171.0	3130.0	5597.0	0.0	27.0	48.0	428.0	736.0	1103.0	-31.0	N/A	14133.0
14	1909.0	1185.0	3175.0	5601.0	0.0	41.0	60.0	436.0	687.0	981.0	-94.0	N/A	13981.0
15	2225.0	1329.0	3552.0	6225.0	0.0	72.0	93.0	432.0	700.0	974.0	-110.0	N/A	15492.0
16	2212.0	1352.0	3640.0	6314.0	0.0	125.0	147.0	439.0	640.0	794.0	-152.0	N/A	15511.0
17	2199.0	1338.0	3622.0	6204.0	0.0	130.0	157.0	455.0	655.0	816.0	-187.0	N/A	15389.0
18	2313.0	1373.0	3625.0	6309.0	0.0	87.0	121.0	473.0	716.0	979.0	-163.0	N/A	15833.0
19	1753.0	1024.0	2877.0	5044.0	0.0	75.0	97.0	337.0	609.0	902.0	-120.0	N/A	12598.0
20	1773.0	1090.0	2942.0	4933.0	0.0	69.0	92.0	357.0	608.0	870.0	-32.0	N/A	12702.0
21	1803.0	1144.0	3027.0	5158.0	0.0	74.0	93.0	372.0	630.0	909.0	-42.0	N/A	13168.0
22	2024.0	1232.0	3350.0	5761.0	0.0	93.0	114.0	418.0	650.0	867.0	-120.0	N/A	14389.0
23	2007.0	1232.0	3307.0	5674.0	0.0	101.0	124.0	384.0	577.0	730.0	-144.0	N/A	13992.0
24	1740.0	1054.0	3043.0	5270.0	0.0	57.0	89.0	404.0	208.0	691.0	-144.0	N/A	12412.0
25	1856.0	1103.0	3101.0	5326.0	0.0	93.0	116.0	416.0	463.0	951.0	-59.0	N/A	13366.0
26	1873.0	1107.0	3112.0	5346.0	0.0	86.0	93.0	427.0	683.0	999.0	-71.0	N/A	13655.0
27	2175.0	1344.0	3433.0	5834.0	0.0	87.0	105.0	452.0	691.0	965.0	-109.0	N/A	14977.0
28	2185.0	1351.0	3446.0	5381.0	0.0	89.0	97.0	406.0	505.0	970.0	-102.0	N/A	14328.0
29	2003.0	1260.0	3278.0	5599.0	0.0	109.0	125.0	407.0	N/A	888.0	-73.0	N/A	13596.0
30	2107.0	1290.0	3488.0	5859.0	0.0	132.0	161.0	406.0	N/A	761.0	-155.0	N/A	14049.0
31	2165.0	1327.0	3501.0	5897.0	0.0	132.0	163.0	127.0	N/A	763.0	-155.0	N/A	13920.0
<b>Monthly T...</b>	<b>62532.00</b>	<b>37836.00</b>	<b>102707.00</b>	<b>178808.00</b>	<b>0.00</b>	<b>2666.00</b>	<b>3353.00</b>	<b>13002.00</b>	<b>17958.00</b>	<b>27469.00</b>	<b>-3568.00</b>	<b>N/A</b>	<b>442763.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports

M\_FlowTotal\_Net\_MCx  
01/10/2025 03:26:00 AM

Report Date From: 01/09/2025 12:00:00 AM

To: 01/10/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	2181.0	1335.0	3732.0	6223.0	0.0	151.0	178.0	152.0	N/A	842.0	-197.0	N/A	14597.0
2	2186.0	1312.0	3745.0	6245.0	0.0	132.0	157.0	476.0	585.0	1077.0	-148.0	N/A	15767.0
3	2066.0	1244.0	3316.0	5833.0	0.0	89.0	109.0	477.0	660.0	1079.0	-86.0	N/A	14787.0
4	2051.0	1248.0	3270.0	5851.0	0.0	82.0	104.0	437.0	660.0	936.0	-61.0	N/A	14578.0
5	1829.0	1100.0	3010.0	5258.0	0.0	81.0	107.0	387.0	661.0	908.0	-32.0	N/A	13309.0
6	1964.0	1209.0	3231.0	5460.0	0.0	108.0	132.0	390.0	584.0	785.0	-60.0	N/A	13803.0
7	2046.0	1237.0	3421.0	5788.0	0.0	134.0	155.0	416.0	588.0	742.0	-118.0	N/A	14409.0
8	2053.0	1240.0	3432.0	5807.0	0.0	130.0	154.0	418.0	667.0	955.0	-70.0	N/A	14786.0
9	1980.0	1170.0	3222.0	5597.0	0.0	72.0	101.0	470.0	708.0	990.0	-73.0	N/A	14237.0
10	2032.0	1242.0	3269.0	5616.0	0.0	69.0	101.0	472.0	703.0	981.0	-87.0	N/A	14398.0
11	2040.0	1247.0	3281.0	5635.0	0.0	87.0	102.0	452.0	730.0	1094.0	-43.0	N/A	14625.0
12	2035.0	1228.0	3299.0	5696.0	0.0	97.0	124.0	423.0	687.0	972.0	-73.0	N/A	14488.0
13	1902.0	1168.0	3268.0	5654.0	0.0	106.0	138.0	408.0	614.0	781.0	-117.0	N/A	13922.0
14	1964.0	1188.0	3392.0	5844.0	0.0	111.0	149.0	427.0	621.0	750.0	-127.0	N/A	14319.0
15	2076.0	1233.0	3403.0	5863.0	0.0	94.0	118.0	453.0	737.0	1061.0	-74.0	N/A	14964.0
16	2077.0	1227.0	3361.0	5742.0	0.0	76.0	116.0	440.0	720.0	1056.0	-68.0	N/A	14747.0
17	2318.0	1436.0	3615.0	6208.0	0.0	103.0	130.0	448.0	727.0	1056.0	-51.0	N/A	15990.0
18	2185.0	1379.0	3412.0	6066.0	0.0	77.0	108.0	440.0	721.0	1056.0	-46.0	N/A	15398.0
19	2100.0	1269.0	3291.0	6074.0	0.0	82.0	118.0	455.0	696.0	988.0	-69.0	N/A	15004.0
20	2120.0	1302.0	3440.0	5894.0	0.0	94.0	126.0	430.0	599.0	760.0	-124.0	N/A	14641.0
21	1912.0	1154.0	3211.0	5518.0	0.0	89.0	134.0	392.0	558.0	702.0	-126.0	N/A	13544.0
22	1890.0	1122.0	3068.0	5389.0	0.0	82.0	108.0	347.0	614.0	920.0	-59.0	N/A	13481.0
23	1974.0	1173.0	3073.0	5504.0	0.0	75.0	99.0	338.0	616.0	920.0	-1.0	N/A	13771.0
24	1896.0	1165.0	3022.0	5538.0	0.0	78.0	95.0	330.0	597.0	884.0	13.0	N/A	13618.0
25	1849.0	1171.0	2940.0	4941.0	0.0	49.0	68.0	336.0	582.0	861.0	-2.0	N/A	12795.0
26	1892.0	1146.0	3059.0	5566.0	0.0	79.0	102.0	336.0	592.0	868.0	-7.0	N/A	13633.0
27	1900.0	1157.0	3118.0	5298.0	0.0	100.0	124.0	362.0	533.0	668.0	-112.0	N/A	13148.0
28	1986.0	1204.0	3261.0	5515.0	0.0	102.0	134.0	365.0	534.0	668.0	-134.0	N/A	13635.0
29	1999.0	1208.0	3272.0	5533.0	0.0	91.0	129.0	405.0	628.0	874.0	-110.0	N/A	14029.0
30	2013.0	1202.0	3208.0	5447.0	0.0	85.0	110.0	407.0	652.0	947.0	-55.0	N/A	14016.0
<b>Monthly T...</b>	<b>60516.00</b>	<b>36716.00</b>	<b>98642.00</b>	<b>170603.00</b>	<b>0.00</b>	<b>2805.00</b>	<b>3630.00</b>	<b>12089.00</b>	<b>18574.00</b>	<b>27181.00</b>	<b>-2317.00</b>	<b>N/A</b>	<b>428439.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports  
M\_FlowTotal\_Net\_MCx  
01/11/2025 03:26:00 AM

Report Date From: 01/10/2025 12:00:00 AM  
To: 01/11/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	2028.0	1239.0	3198.0	5396.0	0.0	89.0	111.0	406.0	671.0	1012.0	-20.0	N/A	14130.0
2	2038.0	1276.0	3211.0	5832.0	0.0	89.0	121.0	398.0	673.0	1014.0	3.0	N/A	14655.0
3	2047.0	1282.0	3222.0	5851.0	0.0	89.0	121.0	403.0	670.0	999.0	-18.0	N/A	14666.0
4	2047.0	1238.0	3317.0	5615.0	0.0	121.0	143.0	405.0	671.0	985.0	-67.0	N/A	14475.0
5	2026.0	1240.0	3326.0	5631.0	0.0	116.0	139.0	393.0	582.0	744.0	-128.0	N/A	14069.0
6	1917.0	1159.0	3246.0	5577.0	0.0	95.0	131.0	385.0	635.0	927.0	-83.0	N/A	13989.0
7	1835.0	1078.0	3037.0	5307.0	0.0	42.0	63.0	360.0	636.0	929.0	-15.0	N/A	13272.0
8	1675.0	1032.0	2780.0	4951.0	0.0	31.0	53.0	345.0	586.0	868.0	-12.0	N/A	12309.0
9	1683.0	1038.0	2791.0	4971.0	0.0	37.0	48.0	360.0	598.0	905.0	-11.0	N/A	12420.0
10	1760.0	1063.0	2850.0	5010.0	0.0	52.0	69.0	360.0	600.0	907.0	-8.0	N/A	12663.0
11	1767.0	1066.0	2860.0	5028.0	0.0	52.0	72.0	343.0	580.0	838.0	-11.0	N/A	12595.0
12	1609.0	954.0	2787.0	4975.0	0.0	71.0	100.0	336.0	506.0	679.0	-62.0	N/A	11955.0
13	1685.0	967.0	2942.0	5209.0	0.0	74.0	99.0	339.0	518.0	629.0	-100.0	N/A	12362.0
14	1626.0	968.0	2711.0	4801.0	0.0	36.0	62.0	355.0	587.0	876.0	-56.0	N/A	11966.0
15	1572.0	984.0	2649.0	4751.0	0.0	-4.0	21.0	359.0	592.0	901.0	13.0	N/A	11838.0
16	1578.0	987.0	2657.0	4767.0	0.0	9.0	19.0	360.0	593.0	920.0	28.0	N/A	11918.0
17	1709.0	1072.0	2747.0	4782.0	0.0	8.0	34.0	356.0	594.0	922.0	23.0	N/A	12247.0
18	1715.0	1076.0	2756.0	4799.0	0.0	8.0	34.0	357.0	595.0	892.0	1.0	N/A	12233.0
19	1421.0	882.0	2572.0	4609.0	0.0	20.0	36.0	316.0	484.0	647.0	-91.0	N/A	10896.0
20	1418.0	887.0	2567.0	4563.0	0.0	14.0	18.0	337.0	643.0	777.0	-45.0	N/A	11179.0
21	1353.0	843.0	2321.0	4178.0	0.0	7.0	33.0	339.0	644.0	855.0	12.0	N/A	10585.0
22	1359.0	847.0	2330.0	4159.0	0.0	16.0	35.0	308.0	553.0	857.0	24.0	N/A	10488.0
23	1378.0	862.0	2349.0	4179.0	0.0	18.0	30.0	307.0	532.0	775.0	11.0	N/A	10441.0
24	1384.0	866.0	2358.0	4195.0	0.0	17.0	29.0	308.0	533.0	773.0	10.0	N/A	10473.0
25	1363.0	850.0	2357.0	4201.0	0.0	16.0	30.0	295.0	517.0	750.0	-13.0	N/A	10366.0
26	1389.0	850.0	2505.0	4404.0	0.0	17.0	36.0	306.0	466.0	594.0	-62.0	N/A	10505.0
27	1359.0	855.0	2514.0	4421.0	0.0	40.0	42.0	308.0	553.0	855.0	5.0	N/A	10952.0
28	1362.0	872.0	2515.0	4260.0	0.0	40.0	40.0	301.0	555.0	857.0	47.0	N/A	10849.0
29	1412.0	881.0	2397.0	4276.0	0.0	8.0	16.0	302.0	531.0	789.0	28.0	N/A	10640.0
30	1226.0	767.0	2223.0	4007.0	0.0	22.0	37.0	279.0	532.0	790.0	23.0	N/A	9906.0
31	1214.0	756.0	2189.0	3917.0	0.0	29.0	37.0	278.0	501.0	714.0	15.0	N/A	9650.0
<b>Monthly T...</b>	<b>49955.00</b>	<b>30737.00</b>	<b>84284.00</b>	<b>148622.00</b>	<b>0.00</b>	<b>1279.00</b>	<b>1859.00</b>	<b>10604.00</b>	<b>17931.00</b>	<b>25980.00</b>	<b>-559.00</b>	<b>N/A</b>	<b>370692.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports  
M\_FlowTotal\_Net\_MCx  
01/12/2025 03:26:00 AM

Report Date From: 01/11/2025 12:00:00 AM  
To: 01/12/2025 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1257.0	775.0	2317.0	4105.0	0.0	31.0	37.0	259.0	488.0	711.0	-11.0	N/A	9969.0
2	1531.0	943.0	2660.0	4619.0	0.0	49.0	60.0	294.0	431.0	542.0	-76.0	N/A	11053.0
3	1538.0	948.0	2668.0	4633.0	0.0	43.0	58.0	298.0	513.0	748.0	-30.0	N/A	11417.0
4	1314.0	808.0	2277.0	4011.0	0.0	-2.0	9.0	299.0	523.0	754.0	10.0	N/A	10003.0
5	1184.0	733.0	2153.0	3789.0	0.0	1.0	15.0	289.0	515.0	755.0	5.0	N/A	9439.0
6	1227.0	763.0	2198.0	3832.0	0.0	18.0	27.0	282.0	506.0	755.0	17.0	N/A	9625.0
7	1233.0	769.0	2206.0	3846.0	0.0	15.0	22.0	279.0	482.0	741.0	9.0	N/A	9602.0
8	1285.0	796.0	2341.0	3833.0	0.0	44.0	53.0	279.0	412.0	665.0	-42.0	N/A	9666.0
9	1292.0	800.0	2360.0	3858.0	0.0	49.0	58.0	281.0	410.0	501.0	-91.0	N/A	9518.0
10	1358.0	842.0	2370.0	3873.0	0.0	38.0	51.0	285.0	476.0	663.0	-64.0	N/A	9892.0
11	1367.0	847.0	2333.0	3827.0	0.0	34.0	21.0	288.0	505.0	727.0	3.0	N/A	9952.0
12	1315.0	809.0	2317.0	3786.0	0.0	9.0	7.0	272.0	512.0	743.0	16.0	N/A	9786.0
13	1369.0	836.0	2322.0	3847.0	0.0	25.0	29.0	277.0	510.0	746.0	21.0	N/A	9982.0
14	1366.0	829.0	2316.0	3884.0	0.0	8.0	14.0	277.0	489.0	697.0	-9.0	N/A	9871.0
15	1291.0	781.0	2350.0	3810.0	0.0	31.0	63.0	248.0	405.0	477.0	-54.0	N/A	9402.0
16	1411.0	856.0	2489.0	4069.0	0.0	31.0	47.0	284.0	407.0	443.0	-102.0	N/A	9935.0
17	1310.0	804.0	2253.0	3718.0	0.0	14.0	16.0	277.0	486.0	699.0	12.0	N/A	9589.0
18	1193.0	733.0	2139.0	3457.0	0.0	-21.0	-13.0	280.0	495.0	704.0	0.0	N/A	8967.0
19	1320.0	812.0	2277.0	3625.0	0.0	-3.0	4.0	274.0	494.0	711.0	16.0	N/A	9530.0
20	1378.0	856.0	2349.0	3678.0	0.0	2.0	10.0	275.0	492.0	712.0	16.0	N/A	9768.0
21	1390.0	862.0	2355.0	3689.0	0.0	6.0	13.0	269.0	467.0	710.0	11.0	N/A	9772.0
22	1369.0	837.0	2439.0	3842.0	0.0	23.0	32.0	261.0	418.0	514.0	-42.0	N/A	9693.0
23	1326.0	814.0	2431.0	3909.0	0.0	39.0	53.0	264.0	403.0	459.0	-78.0	N/A	9620.0
24	1284.0	789.0	2259.0	3745.0	0.0	-3.0	2.0	268.0	489.0	693.0	-29.0	N/A	9497.0
25	1256.0	775.0	2231.0	3662.0	0.0	-6.0	2.0	265.0	481.0	677.0	4.0	N/A	9347.0
26	1262.0	779.0	2165.0	3674.0	0.0	-5.0	3.0	305.0	552.0	829.0	39.0	N/A	9603.0
27	1194.0	735.0	2146.0	3582.0	0.0	4.0	8.0	329.0	575.0	866.0	60.0	N/A	9499.0
28	1207.0	743.0	2164.0	3504.0	0.0	14.0	19.0	280.0	519.0	788.0	44.0	N/A	9282.0
29	1167.0	707.0	2223.0	3550.0	0.0	15.0	20.0	298.0	475.0	620.0	-29.0	N/A	9046.0
30	1171.0	711.0	2270.0	3645.0	0.0	31.0	45.0	292.0	464.0	591.0	-36.0	N/A	9184.0
<b>Monthly T...</b>	<b>39165.00</b>	<b>24092.00</b>	<b>69378.00</b>	<b>114902.00</b>	<b>0.00</b>	<b>534.00</b>	<b>785.00</b>	<b>8428.00</b>	<b>14394.00</b>	<b>20241.00</b>	<b>-410.00</b>	<b>N/A</b>	<b>291509.00</b>



Monthly Report  
Meter Chamber  
Net Flow Totals

Town of Tecumseh  
Water System  
Reports  
M\_FlowTotal\_Net\_MCx  
01/01/2026 03:26:00 AM

Report Date From: 01/12/2025 12:00:00 AM  
To: 01/01/2026 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1229.0	749.0	2202.0	3554.0	0.0	-10.0	-5.0	324.0	558.0	825.0	24.0	N/A	9450.0
2	1304.0	803.0	2265.0	3623.0	0.0	-10.0	-4.0	321.0	564.0	847.0	42.0	N/A	9755.0
3	1456.0	899.0	2426.0	3863.0	0.0	18.0	26.0	307.0	577.0	897.0	78.0	N/A	10547.0
4	1348.0	824.0	2305.0	3740.0	0.0	4.0	8.0	325.0	567.0	838.0	40.0	N/A	9999.0
5	1286.0	792.0	2259.0	3719.0	0.0	-27.0	-19.0	318.0	549.0	813.0	40.0	N/A	9730.0
6	1358.0	826.0	2461.0	4276.0	0.0	2.0	14.0	306.0	482.0	648.0	-20.0	N/A	10353.0
7	1320.0	824.0	2517.0	4051.0	0.0	22.0	35.0	304.0	483.0	633.0	-46.0	N/A	10143.0
8	1233.0	756.0	2229.0	3649.0	0.0	-19.0	-11.0	347.0	612.0	953.0	38.0	N/A	9787.0
9	1223.0	747.0	2195.0	3603.0	0.0	-7.0	2.0	310.0	594.0	924.0	82.0	N/A	9673.0
10	1239.0	754.0	2099.0	3616.0	0.0	-21.0	-9.0	311.0	358.0	926.0	74.0	N/A	9347.0
11	1112.0	679.0	2105.0	3514.0	0.0	-49.0	-51.0	328.0	595.0	905.0	57.0	N/A	9195.0
12	742.0	445.0	1732.0	2997.0	0.0	-63.0	-50.0	329.0	554.0	906.0	60.0	N/A	7652.0
13	738.0	429.0	1837.0	3116.0	0.0	-42.0	-26.0	317.0	511.0	814.0	54.0	N/A	7748.0
14	766.0	442.0	1884.0	3236.0	0.0	-40.0	-16.0	309.0	480.0	706.0	-15.0	N/A	7752.0
15	774.0	448.0	1654.0	3247.0	0.0	-69.0	-40.0	321.0	542.0	838.0	26.0	N/A	7741.0
16	667.0	397.0	1660.0	2917.0	0.0	-82.0	-68.0	353.0	806.0	877.0	39.0	N/A	7566.0
17	649.0	381.0	1656.0	2905.0	0.0	-69.0	-54.0	345.0	578.0	877.0	48.0	N/A	7316.0
18	628.0	378.0	1651.0	2883.0	0.0	-56.0	-30.0	345.0	606.0	935.0	76.0	N/A	7416.0
19	657.0	380.0	1679.0	2951.0	0.0	-36.0	-2.0	295.0	528.0	767.0	34.0	N/A	7253.0
20	720.0	411.0	1807.0	3160.0	0.0	-30.0	5.0	305.0	496.0	651.0	-23.0	N/A	7502.0
21	651.0	401.0	1816.0	3175.0	0.0	-36.0	3.0	329.0	495.0	641.0	-47.0	N/A	7428.0
22	655.0	382.0	1681.0	2935.0	0.0	-53.0	-9.0	322.0	534.0	773.0	22.0	N/A	7242.0
23	677.0	394.0	1734.0	3017.0	0.0	-44.0	6.0	319.0	536.0	789.0	32.0	N/A	7460.0
24	701.0	400.0	1809.0	3151.0	0.0	-11.0	29.0	303.0	518.0	741.0	8.0	N/A	7649.0
25	758.0	431.0	1741.0	3005.0	0.0	-16.0	25.0	262.0	448.0	578.0	-45.0	N/A	7187.0
26	719.0	417.0	1720.0	2947.0	0.0	-30.0	19.0	283.0	458.0	604.0	-41.0	N/A	7096.0
27	721.0	423.0	1775.0	3048.0	0.0	-30.0	16.0	311.0	470.0	598.0	-48.0	N/A	7284.0
28	602.0	362.0	1682.0	2924.0	0.0	-34.0	0.0	323.0	470.0	587.0	-54.0	N/A	6862.0
29	602.0	362.0	1652.0	2909.0	0.0	-33.0	-18.0	312.0	504.0	708.0	5.0	N/A	7003.0
30	773.0	459.0	1779.0	3070.0	0.0	7.0	17.0	290.0	492.0	688.0	5.0	N/A	7580.0
31	719.0	422.0	1762.0	3054.0	0.0	-18.0	-6.0	307.0	477.0	623.0	-34.0	N/A	7306.0
<b>Monthly T...</b>	<b>28027.00</b>	<b>16817.00</b>	<b>59774.00</b>	<b>101855.00</b>	<b>0.00</b>	<b>-882.00</b>	<b>-213.00</b>	<b>9781.00</b>	<b>16442.00</b>	<b>23910.00</b>	<b>511.00</b>	<b>N/A</b>	<b>256022.00</b>