

**Ministry of the Environment,
Conservation and Parks**

Drinking Water and Environmental
Compliance Division

Southwest Region
733 Exeter Road
London, ON N6E 1L3
Phone: 519-873-5000

**Ministère de l'Environnement, de la
Protection de la nature et des Parcs**

Division de la conformité en matière d'eau
potable et d'environnement

Région Sud-Ouest
733 rue Exeter
London, ON N6E 1L3
Tél: 519-873-5000

March 25, 2025

The Corporation of the Town of Tecumseh
917 Lesperance Rd ,
Tecumseh, ON,
N8N 1W9

Attention: Brad Dupuis, Water & Wastewater Manager

Re: Tecumseh Drinking Water System Inspection Report (WW# 260004969)
Inspection conducted on February 26, 2025

Brad,

Enclosed is the report on the 2024-25 inspection and the corresponding Inspection Rating Report (IRR) and Risk Methodology document.

Section 19 of the Safe Drinking Water Act (Standard of Care) creates a number of obligations for individuals who exercise decision-making authority over municipal drinking water systems. Please be aware that the Ministry has encouraged such individuals, particularly municipal councillors, to take steps to be better informed about the drinking water systems over which they have decision-making authority. These steps could include asking for a copy of this inspection report and a review of its findings. Further information about Section 19 can be found in "Taking Care of Your Drinking Water: A Guide for Members of Municipal Councils" on the Drinking Water Ontario website at <https://www.ontario.ca/environment-and-energy/taking-care-your-drinking-water-guide-membersmunicipalcouncils>.

The IRR is a summarized quantitative measure of the drinking water system's annual inspection and is published in the Ministry's Chief Drinking Water Inspector's Annual Report. The Risk Methodology document describes the risk rating methodology which has been applied to the findings of the Ministry's municipal residential drinking water system inspection results.

If you have any questions regarding the report, please feel free to call me at (519) 671-2343.
Yours truly,



Steve Dunn
Provincial Officer
London District Office
stephen.dunn@ontario.ca

cc. Windsor-Essex County Health Unit
Essex Region Conservation Authority



TECUMSEH DISTRIBUTION SYSTEM
Physical Address: , , ,

INSPECTION REPORT

Entity: THE CORPORATION OF THE
TOWN OF TECUMSEH
Inspection Start Date: January 11, 2025
Inspection End Date: March 25, 2025
Inspected By: Stephen Dunn
Badge #: 1097



(signature)

NON-COMPLIANCE

This should not be construed as a confirmation of full compliance with all potential applicable legal requirements. These inspection findings are limited to the components and/or activities that were assessed, and the legislative framework(s) that were applied. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

If you have any questions related to this inspection, please contact the signed Provincial Officer.

RECOMMENDATIONS

The following item(s) have been identified as non-conformance, based on a "No" response captured for a best management practice (BMP) question(s). For additional information on each question see the Inspection Details section of the report.

Ministry Program: DRINKING WATER | **Regulated Activity:** DW Municipal Residential

Item	Question	Recommendation(s)
R-1	<p>Question ID: DWMR1070001</p> <p>Were air vents and overflows associated with reservoirs and elevated storage structures equipped with screens?</p>	<p>Air vents and overflows associated with reservoirs and elevated storage structures were not equipped with screens.</p> <p>Best Management Practice</p> <p>It is recommended that a #4 mesh (5.16 mm) non-corrodible screen is installed on the overflow of the water tower as per The Ten States Standards.</p>

INSPECTION DETAILS

This section includes all questions that were assessed during the inspection.

Ministry Program: DRINKING WATER | **Regulated Activity:** DW Municipal Residential

Question ID	DWMR1018001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Did the owner ensure that equipment was installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner ensured that equipment was installed as required.			

Question ID	DWMR1020001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Were Form 1 documents prepared as required?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Form 1 documents were prepared as required.			

Question ID	DWMR1025001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Were all parts of the drinking water system that came in contact with drinking water disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): All parts of the drinking water system were disinfected as required.			

Question ID	DWMR1027001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Did the owner have evidence indicating that chemicals and materials that came in contact with water within the drinking water system met all applicable AWWA and ANSI standards in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner had evidence indicating that chemicals and materials that came in contact with water within the drinking water system met the applicable standards.			

Question ID	DWMR1033001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 7-2 (3); SDWA O. Reg. 170/03 7-2 (4);			
Question: Was secondary disinfectant residual tested as required for the large municipal residential distribution system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Secondary disinfectant residual was tested as required.			

Question ID	DWMR1049001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Did records confirm that disinfectant residuals were routinely checked at the extremities and dead ends of the distribution system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Records confirmed that disinfectant residuals were routinely checked at the extremities and dead ends of the distribution system.			

Question ID	DWMR1036001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 6-7 (1);			
Question: Where continuous monitoring equipment was not used for chlorine residual analysis, were			

samples tested using an acceptable portable device?

Compliance Response(s)/Corrective Action(s)/Observation(s):

Samples for chlorine residual analysis were tested using an acceptable portable device.

Question ID	DWMR1099001	Question Type	Information
Legislative Requirement(s): Not Applicable			
Question: Do records show that water provided by the drinking water system met the Ontario Drinking Water Quality Standards?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Records showed that all water sample results met the Ontario Drinking Water Quality Standards.			

Question ID	DWMR1081001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 10-2 (1); SDWA O. Reg. 170/03 10-2 (2); SDWA O. Reg. 170/03 10-2 (3);			
Question: Were distribution microbiological sampling requirements prescribed by Schedule 10-2 of O. Reg. 170/03 for large municipal residential systems met?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Distribution microbiological sampling requirements were met.			

Question ID	DWMR1096001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 6-3 (1);			
Question: Did records confirm that chlorine residual tests were conducted at the same time and location as microbiological samples?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Records confirmed that chlorine residual tests were conducted as required.			

Question ID	DWMR1086001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 13-6.1 (1); SDWA O. Reg. 170/03 13-6.1 (2); SDWA O. Reg. 170/03 13-6.1 (3); SDWA O. Reg. 170/03 13-6.1 (4); SDWA O. Reg. 170/03 13-6.1 (5); SDWA O. Reg. 170/03 13-6.1 (6);			
Question: Were haloacetic acid sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Haloacetic acid sampling requirements were met.			

Question ID	DWMR1087001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 13-6 (1); SDWA O. Reg. 170/03 13-6 (2); SDWA O. Reg. 170/03 13-6 (3); SDWA O. Reg. 170/03 13-6 (4); SDWA O. Reg. 170/03 13-6 (5); SDWA O. Reg. 170/03 13-6 (6);			
Question: Were trihalomethane sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Trihalomethane sampling requirements were met.			

Question ID	DWMR1092001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 6-2;			
Question: Were water samples taken at the prescribed location?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Water samples were taken at the prescribed location.			

Question ID	DWMR1095001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 15.1-10; SDWA O. Reg. 170/03 15.1-4 (1); SDWA O. Reg. 170/03 15.1-5 (1); SDWA O. Reg. 170/03 15.1-5 (10); SDWA O. Reg. 170/03 15.1-5			

| (11); SDWA | O. Reg. 170/03 | 15.1-5 | (2); SDWA | O. Reg. 170/03 | 15.1-5 | (3); SDWA | O. Reg. 170/03 | 15.1-5 | (4); SDWA | O. Reg. 170/03 | 15.1-5 | (5); SDWA | O. Reg. 170/03 | 15.1-5 | (6); SDWA | O. Reg. 170/03 | 15.1-5 | (7); SDWA | O. Reg. 170/03 | 15.1-5 | (8); SDWA | O. Reg. 170/03 | 15.1-5 | (9); SDWA | O. Reg. 170/03 | 15.1-7 | (1); SDWA | O. Reg. 170/03 | 15.1-7 | (2); SDWA | O. Reg. 170/03 | 15.1-7 | (3); SDWA | O. Reg. 170/03 | 15.1-7 | (4); SDWA | O. Reg. 170/03 | 15.1-9 | (1); SDWA | O. Reg. 170/03 | 15.1-9 | (2); SDWA | O. Reg. 170/03 | 15.1-9 | (3); SDWA | O. Reg. 170/03 | 15.1-9 | (4); SDWA | O. Reg. 170/03 | 15.1-9 | (5); SDWA | O. Reg. 170/03 | 15.1-9 | (6); SDWA | O. Reg. 170/03 | 15.1-9 | (7); SDWA | O. Reg. 170/03 | 15.1-9 | (8); SDWA | O. Reg. 170/03 | 15.1-9 | (9);

Question:

Were lead sampling requirements prescribed by Schedule 15.1 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):

Lead sampling requirements were met.

Question ID	DWMR1110001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 11 (6);			
Question: Was the annual report prepared by February 28th of the following year and did it contain the required information?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The annual report requirements were met.			

Question ID	DWMR1057001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 11 (2.1);			
Question: Did the owner of this system provide an annual report to the owner(s) of all standalone distribution systems connected to this system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner provided an annual report to the standalone distribution system(s) connected to this system.			

Question ID	DWMR1056001	Question Type	Information
Legislative Requirement(s): Not Applicable			

Question:

Did the donor provide an annual report to the owner of this receiver drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):

The donor provided an annual report to the owner of the receiver drinking water system.

Question ID	DWMR1111001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 22-2 (1); SDWA O. Reg. 170/03 22-2 (2); SDWA O. Reg. 170/03 22-2 (3); SDWA O. Reg. 170/03 22-2 (4);			
Question: Did the summary report contain the required information and was it completed and distributed as required?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The summary report requirements were met.			

Question ID	DWMR1114001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Did the owner have evidence that, when required, all legal owners associated with the drinking water system were notified of the requirements of the Municipal Drinking Water Licence and Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner had evidence that the required notifications were made.			

Question ID	DWMR1098001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 13 (1); SDWA O. Reg. 170/03 13 (2); SDWA O. Reg. 170/03 13 (3);			
Question: Were the required records kept for the periods prescribed by section 13 of O. Reg. 170/03?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The required records were kept for the prescribed periods.			

Question ID	DWMR1045001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			
Question: Did the owner update the document describing the distribution components within 12 months of completion of alterations to the system in accordance with the Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner had up-to-date documents describing the distribution components.			

Question ID	DWMR1046001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was there a backflow prevention program, policy and/or bylaw in place that addressed cross connections and connections to high hazard facilities?			
Compliance Response(s)/Corrective Action(s)/Observation(s): There was a backflow prevention program, policy and/or bylaw in place. The Town of Tecumseh's By-law #2024-099 is a by-law which regulates cross-contamination and backflow prevention in private plumbing systems to protect the Town of Tecumseh's water supply system from contamination.			

Question ID	DWMR1053001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was the owner able to maintain proper pressures in the distribution system and was pressure monitored to alert the operator of conditions of loss of pressure below the value under which the system was designed to operate?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner was able to maintain proper pressures in the distribution system and pressure was monitored to alert the operator of conditions which may lead to loss of pressure below the value under which the system is designed to operate.			

Question ID	DWMR1047001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Did the owner have a program or maintain a schedule for routine cleanout, inspection and maintenance of reservoirs and elevated storage tanks within the distribution system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner had a program or maintained a schedule for routine cleanout, inspection and maintenance of reservoirs and elevated storage tanks within the distribution system.			

Question ID	DWMR1048001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Had the owner implemented a program for the flushing of watermain as per industry standards?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner had implemented a program for the flushing of watermain.			

Question ID	DWMR1050001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was there a program in place for inspecting and exercising valves?			
Compliance Response(s)/Corrective Action(s)/Observation(s): There was a program in place for inspecting and exercising valves.			

Question ID	DWMR1051001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was there a program in place for inspecting and operating hydrants?			
Compliance Response(s)/Corrective Action(s)/Observation(s): There was a program in place for inspecting and operating hydrants.			

--

Question ID	DWMR1052001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was there a bylaw or policy in place limiting access to hydrants?			
Compliance Response(s)/Corrective Action(s)/Observation(s): There was a bylaw or policy in place limiting access to hydrants. The Town of Tecumseh's Water-Use By-law #2003-99 (Parts 7.3 and 11) contain conditions with respect to the use and restriction of hydrants.			

Question ID	DWMR1058001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 28;			
Question: Did operators and maintenance personnel have ready access to operations and maintenance manuals?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Operators and maintenance personnel had ready access to operations and maintenance manuals.			

Question ID	DWMR1059001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 28;			
Question: Did the operations and maintenance manuals contain plans, drawings, and process descriptions sufficient for the safe and efficient operation of the system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The operations and maintenance manuals contained plans, drawings, and process descriptions sufficient for the safe and efficient operation of the system.			

Question ID	DWMR1060001	Question Type	Legislative
Legislative Requirement(s): SDWA 31 (1);			

Question:

Did the operations and maintenance manual(s) meet the requirements of the Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):

The operations and maintenance manual(s) met the requirements of the Municipal Drinking Water Licence.

Question ID	DWMR1062001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 7-5;			
Question: Did records or other record keeping mechanisms confirm that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03.			

Question ID	DWMR1063001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 170/03 6-10 (1);			
Question: For every required operational test and sample, was a record made of the date, time, location, results, and name of the person conducting the test?			
Compliance Response(s)/Corrective Action(s)/Observation(s): For every required operational test and sample, a record was made as required.			

Question ID	DWMR1061001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 27 (1); SDWA O. Reg. 128/04 27 (2); SDWA O. Reg. 128/04 27 (3); SDWA O. Reg. 128/04 27 (4); SDWA O. Reg. 128/04 27 (5); SDWA O. Reg. 128/04 27 (6); SDWA O. Reg. 128/04 27 (7);			
Question: Were logbooks properly maintained and did they contain the required information?			

Compliance Response(s)/Corrective Action(s)/Observation(s):

Logbooks were properly maintained and contained the required information.

Question ID	DWMR1065001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 27 (6);			
Question: Were logs and other record keeping mechanisms available for at least five (5) years?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Logs or other record keeping mechanisms were available for at least five (5) years.			

Question ID	DWMR1069001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Were all storage facilities completely covered and secure?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Storage facilities were completely covered and secure.			

Question ID	DWMR1070001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Were air vents and overflows associated with reservoirs and elevated storage structures equipped with screens?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Air vents and overflows associated with reservoirs and elevated storage structures were not equipped with screens. Best Management Practice It is recommended that a #4 mesh (5.16 mm) non-corrodible screen is installed on the overflow of the water tower as per The Ten States Standards.			

Question ID	DWMR1071001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Did the owner provide security measures to protect components of the drinking water system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner provided security measures to protect components of the drinking water system.			

Question ID	DWMR1072001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Had the owner and/or operating authority undertaken efforts to promote water conservation and reduce water losses in the drinking water system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner and/or operating authority undertook efforts to promote water conservation and reduce water losses in their system.			

Question ID	DWMR1073001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 23 (1);			
Question: Was an overall responsible operator designated for all subsystems which comprise the drinking water system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): An overall responsible operator was designated for all subsystem.			

Question ID	DWMR1078001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 23 (1); SDWA O. Reg. 128/04 23 (2); SDWA O. Reg. 128/04 23 (4); SDWA O. Reg. 128/04 23 (6); SDWA O. Reg. 128/04 23 (7);			
Question: When the overall responsible operator was unable to act, was a properly certified operator designated to act in their place?			

Compliance Response(s)/Corrective Action(s)/Observation(s):

A properly certified operator was designated to act in place of the overall responsible operator.

Question ID	DWMR1074001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 25 (1);			
Question: Were operators-in-charge designated for all subsystems which comprise the drinking water system?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Operators-in-charge were designated for all subsystems.			

Question ID	DWMR1075001	Question Type	Legislative
Legislative Requirement(s): SDWA O. Reg. 128/04 22;			
Question: Were all operators certified as required?			
Compliance Response(s)/Corrective Action(s)/Observation(s): All operators were certified as required.			

Key Reference and Guidance Material for Municipal Residential Drinking Water Systems

Many useful materials are available to help you operate your drinking water system. Below is a list of key materials owners and operators of municipal residential drinking water systems frequently use.

To access these materials online click on their titles below or use your web browser to search for their titles. Contact the Ministry if you need assistance or have questions at 1-866-793-2588 or

waterforms@ontario.ca.

For more information on Ontario's drinking water visit

www.ontario.ca/page/drinking-water



Click on the publication below to access it

- [Drinking Water System Profile Information Form - 012-2149E](#)
- [Laboratory Services Notification Form – 012-2148E](#)
- [Adverse Test Result Notification Form – 012-4444E](#)
- [Taking Care of Your Drinking Water: A Guide for Members of Municipal Councils](#)
- [Procedure for Disinfection of Drinking Water in Ontario](#)
- [Strategies for Minimizing the Disinfection Products Trihalomethanes and Haloacetic Acids](#)
- [Filtration Processes Technical Bulletin](#)
- [Ultraviolet Disinfection Technical Bulletin](#)
- [Guide for Applying for Drinking Water Works Permit Amendments, & License Amendments](#)
- [Certification Guide for Operators and Water Quality Analysts](#)
- [Training Requirements for Drinking Water Operator](#)
- [Community Sampling and Testing for Lead: Standard and Reduced Sampling and Eligibility for Exemption](#)
- [Drinking Water System Contact List – 7128E01](#)
- [Ontario's Drinking Water Quality Management Standard - Pocket Guide](#)
- [2020 Watermain Disinfection Procedure](#)
- [List of Licensed Laboratories](#)

Ministry of the Environment, Conservation and Parks - Inspection Summary Rating Record (Reporting Year - 2024-25)

DWS Name: TECUMSEH DISTRIBUTION SYSTEM

DWS Number: 260004969

DWS Owner: THE CORPORATION OF THE TOWN OF TECUMSEH

Municipal Location: TECUMSEH

Regulation: O.REG. 170/03

DWS Category: DW Municipal Residential

Type of Inspection: Detailed

Compliance Assessment Start Date: Jan-11-2025

Ministry Office: Windsor Area Office

Maximum Risk Rating: 270

Inspection Module	Non Compliance Risk (X out of Y)
Certification and Training	0/35
Distribution System	0/8
Logbooks	0/26
Operations Manuals	0/42
Reporting & Corrective Actions	0/12
Treatment Processes	0/76
Water Quality Monitoring	0/71
Overall - Calculated	0/270

Inspection Risk Rating:	0.00%
--------------------------------	--------------

Final Inspection Rating:	100.00%
---------------------------------	----------------

DWS Name: TECUMSEH DISTRIBUTION SYSTEM
DWS Number: 260004969
DWS Owner Name: THE CORPORATION OF THE TOWN OF TECUMSEH
Municipal Location: TECUMSEH

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Detailed
Compliance Assessment Start Date: Jan-11-2025
Ministry Office: Windsor Area Office

All legislative requirements were met. No detailed rating scores.

Maximum Question Rating: 270

Inspection Risk Rating: 0.00%

FINAL INSPECTION RATING: 100.00%